

Number	23-003592-PR02 (NW-A01-0203-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Lift-sliding door, scheme G
Designation	System: SL2700 Shipping name: Sliding lift & slide system
Details	Manufacturer ALUMINCO S.A., Inofita Viotias; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction To the left (seen from inside); Overall dimensions (W x H) 4040 mm x 2565 mm
Special features	Test sequence. Increased operating forces. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage. The strength, durability and material compatibility of the adhesive system was not part of this test and must be tested separately if necessary.

Result **)

Operating forces according to EN 13115:2020-08



Class: 0

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 5A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

22.12.2023



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Alexandros Simeonidis, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
(e.g. DIN EN)

Test report: 23-003592-PR02 PB-
A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 914-81708