

Number	18-003621-PR02 (NW-C01-02-en-02)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Double leaf external pedestrian doorset with opening meeting stile
Designation	Shipping name: D75
Details	Material Aluminium system with thermal break; Overall dimensions (W x H) 2000 x 2400 ; Closing condition closed and locked; Face 2 Closing face; Threshold: Designation 075-902; System D75; Material Aluminium system with thermal break; Lock: Designation AS 3500
Special features	Test sequence. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account.

### Result

Air permeability according to EN 12207:2016-12



**Class: 3**

Resistance to wind load according to EN 12210:2016-03



**Class: C1/B1**

Watertightness according to EN 12208:1999-11



**Class: 5A**

ift Rosenheim

06.03.2019



Michael Breckl-Stock  
Deputy Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09

\*) and corresponding national versions  
e.g. DIN EN

Test report: 18-003621-PR02 PB-C01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 018-02690