

Number	23-002574-PR01 (NW-E01-02-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Pergola Awning
Designation	System: PERGOLA BIOCLIMATIC Shipping name: BIOCLIMATE PERGOLA ROOFTOP
Details	Manufacturer ift Hellas P.C., Oreokastro; Material Aluminium; Overall dimensions (W x H) 2,595 mm x 3,200 mm; Clear opening 2,460 mm x 2,850 mm; Cross section (L x W) 2,440 mm x 215 mm; Cross section (H x D) 50 mm x 215 mm; Drive Motor
Special features	Fixed slats, non-retractable pergola awning

Result **)

Resistance to wind loads according to EN 13561 - Classification according to EN 13561:2015-05 + AC:2016-03



B_{2,460 mm} X H_{2,850 mm} **Klasse 6**

Resistance of non-retractable elements to pressure loads according to EN 13561:2015-05 + AC:2016-03



B_{2,460 mm} X H_{2,850 mm} **Pass**

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
22.12.2023



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Alexandros Simeonidis, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 13659-2004+A1:2008-10

EN 13659:2015-05

*) and corresponding national versions
(e.g. DIN EN)

Test report: 23-002574-PR01 PB-
E01-02-en-01

Representation



Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: DDE-A8A37