

Evidence of Performance

Thermal transmittance

Test report 426 36647/2e

Translation of test report 426 36647/2 dated 06 November 2008



Client **ALUMINCO S.A.**
Megali Rahi

32011 Inofita Viotias
Greece


Product	Door panel with double-sided covering and glazing section
Designation	P 6253
Thickness	Panel: 22.8 / 34.8 mm Insulation glazing: 18.5 mm
Dimensions W x H	900 mm x 2100 mm
Opaque filling	Panel Aluminium: 1.4 mm Extruded polystyrene-hard foam (XPS): 20 mm / 32.0 mm Aluminium: 1.4 mm
Surface	powder coated / anodised Insulating glass unit Construction: 4/8.5/6 mm Gas filling: Air Spacer: Aluminium
Transparent filling	
Special features	-

Basis

EN ISO 6946: 2003
Building components and building elements - Thermal resistance and thermal transmittance - Calculation method
EN ISO 10211: 2008
Thermal bridges in building construction - Heat flows and surface temperatures - Detailed calculations

Test report 426 36647 dated 06 November 2008

Representation



Instructions for use

The present test report serves to demonstrate the thermal transmittance U_p .

Validity

The data and results provided refer solely to the tested and described object.

The determination of the thermal transmittance does not allow any statement to be made on further characteristics regarding performance and quality of the existing construction.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 7 pages

- 1 Object
- 2 Procedure
- 3 Detailed results

Thermal transmittance



$$U_p = 1.82 \text{ W}/(\text{m}^2 \cdot \text{K})$$



ift Rosenheim
18 December 2008

Konrad Huber
Konrad Huber, Dipl.-Ing. (FH)
Assistant Head of Testing Department
ift Centre Glass, Building Materials & Building Physics

Klaus Specht
Klaus Specht, Dipl.-Ing. (FH)
Test engineer
ift Centre Glass, Building Materials & Building Physics



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18
DAP-PL-0808 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-00